



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007589

Product Residual Current Operated Circuit Breaker

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NXBLE-125,NXBLG-125;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-21D0120-S, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Feb.21,2022

Valid until: Feb.20,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE220303007589

NXBLE-125, NXBLG-125

Ui:500V; Uimp:4kV;

Ue: AC220V/230V/240V(1P+N,2P), AC380V/400V/415V(3P,3P+N,4P);

In: 63A,80A,100A,125A(1P+N,2P); 63A,80A,100A(3P,3P+N,4P);

Over-current Release Type: Thermal Magnetic;

Ics=7.5kA, Icu=10kA;

I Δ n: NXBLE-125(Type AC), NXBLG-125(Type AC):0.03A,0.05A,0.075A,0.1A,0.3A;

NXBLE-125(Type A): 0.03A, 0.1A,0.3A;

I Δ m: 2.5kA;

Selectivity Category: A;

Residual current Type: Electronic;

Number of poles:

NXBLE-125: 1P+N(1 protected pole with a switched neutral pole),

2P,3P,3P+N(3 protected poles with a switched neutral pole), 4P;

NXBLG-125: 1P+N(1 protected pole with a switched neutral pole), 2P;

1P+N, 3P+N: not suitable for isolation.



CHINA QUALITY CERTIFICATION CENTRE

