

# ATTESTATION OF CONFORMITY

Issued to: Zhejiang CHINT Building Electric Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixing, Yueqing, Zhejiang,  
P.R.China

For the product: fixed socket-outlets, (2-pole with side earthing)

Trade name: CHINT

Type/Model: AC30-111

Ratings: 250 V~; 16 A; rewirable

Manufactured by: Zhejiang CHINT Building Electric Co., Ltd.  
Wenzhou Bridge Industrial Zone, Yueqing City, Zhejiang Province, P.R.China

Requirements: IEC 60884-1:2002+A1:2006+A2:2013  
DIN VDE 0620-1:2013

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no.3169018.50

The examination has been carried out on one single specimen of the product, submitted by the manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 15 September 2015

Number: 3169018.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

C. Lin  
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed