

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

**Holder of Certificate:** **Xiamen Kehua Digital Energy  
Tech Co., Ltd.**

Room 208-38, Hengye Building  
No. 100 Xiangxing Road  
Torch High-tech Zone  
(Xiangan) Industrial Zone  
361115 Xiamen  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Converter  
(Hybrid Inverter)**

**Model(s):** **iStoragE 3600, iStoragE 5000  
iStoragE 3600E, iStoragE 5000E  
iStoragE1 3600, iStoragE1 5000**

**Parameters:** See page 2

**Applicable standards:** VDE-AR-N 4105:2018  
DIN VDE V 0124-100 (VDE V 0124-100):2020

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290223121701

**Date,** 2022-11-28



( Billy Qiu )

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

## Parameters

Max. Input Voltage:	580 Vd.c.
Min. MPP Voltage:	100 Vd.c.
Max. MPP Voltage:	550 Vd.c.
Max. DC Current:	2*15 Ad.c.
Isc PV:	2*18.75 Ad.c.
Battery Voltage Range	85 ~ 450 Vd.c. ( iStoragE 3600, iStoragE 5000, iStoragE 3600E, iStoragE 5000E ) 360V~500 Vd.c. ( iStoragE1 3600, iStoragE1 5000)
Maximum Battery Charge/Discharge current:	32 Ad.c. ( iStoragE 3600, iStoragE 5000, iStoragE 3600E, iStoragE 5000E ) 25 Ad.c. ( iStoragE1 3600, iStoragE1 5000)
Maximum Battery Charge/Discharge Power:	4600 W ( iStoragE 5000, iStoragE 5000E, iStoragE1 5000) 3600 W ( iStoragE 3600, iStoragE 3600E, iStoragE1 3600)
Rated Grid Voltage:	230 Va.c.
Rated Grid Frequency:	50 Hz
Max. Current Output to Grid:	20.0 Aa.c. ( iStoragE 5000, iStoragE 5000E, iStoragE1 5000) 15.6 Aa.c. ( iStoragE 3600, iStoragE 3600E, iStoragE1 3600)
Rated Active Power to Grid:	4600 W ( iStoragE 5000, iStoragE 5000E, iStoragE1 5000) 3600 W ( iStoragE 3600, iStoragE 3600E, iStoragE1 3600)
Max. Apparent Power to Grid:	4600 VA ( iStoragE 5000, iStoragE 5000E, iStoragE1 5000) 3600 VA ( iStoragE 3600, iStoragE 3600E, iStoragE1 3600)
Max. Apparent Power from Grid:	4600 VA ( iStoragE 5000, iStoragE 5000E, iStoragE1 5000) 3600 VA ( iStoragE 3600, iStoragE 3600E, iStoragE1 3600)
Power Factor Range:	0.9 leading to 0.9 lagging

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

## E.4 Unit certificate

Unit Certificate		
<b>Manufacturer</b>	Xiamen Kehua Digital Energy Tech Co., Ltd.	
<b>Power generation unit type</b>	[Inverter]: iStoragE 3600, iStoragE 5000, iStoragE 3600E, iStoragE 5000E, iSorageE1 3600, iStoragE1 5000. Remark: certified on representative model iStoragE 5000 of family design products, results of the measurement of iStoragE 5000 can be transferred to other models based on transferability rule of measurements in DIN VDE V 0124-100 (VDE V 0124-100):2020.	
<b>Technical data</b>	Max. active power $P_{E_{max}}$	4600 W (iStoragE 5000)
	Max. apparent power $S_{E_{max}}$	4600 VA (iStoragE 5000)
	Rated voltage	230 Va.c.
	Rated current (AC) $I_r$	20.0 A (iStoragE 5000)
	Initial short-circuit AC current $I''_k$	20.0 A (iStoragE 5000)
<b>Network connection rule</b>	<b>VDE-AR-N 4105 “Generators connected to the low-voltage distribution network”</b> Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network	
<b>Test requirement</b>	<b>DIN VDE V 0124-100 (VDE V 0124-100) “Network integration of power generation systems – Low voltage”</b> Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network	
<b>Test report</b>	64.290.22.31217.01 from 2022.11.14	
The above designated power generation unit meets the requirements of VDE-AR-N 4105		

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

## E.5 Test report "Network interactions" for generating units with an input current >75 A

Extract from test report for unit certificate "Determination of electrical properties"		
Generation unit manufacturer:	Xiamen Kehua Digital Energy Tech Co., Ltd.	
Manufacturer indications:	Type of system	Energy Storage Inverter for PV system
	Max. active power $P_{E_{max}}$	3600 W (iStoragE 3600, iStoragE 3600E, iStoragE1 3600) 4600 W (iStoragE 5000, iStoragE 5000E, iStoragE1 5000)
	Rated voltage	230 Va.c.
Period of measurement:	From 2021-09-09 to 2022-01-21, 2022-10-09 to 2022-10-31	

Rapid voltage changes	
Connection without provisions (regarding the primary energy carrier)	$K_i=0.50$
Most adverse case when switching between generator levels	$K_i=0.99$
Connection at nominal conditions (of the primary energy carrier)	$K_i=0.99$
Disconnection at rated power	$K_i=0.99$
Worst value of all switching operations	$K_{i_{max}}=0.99$

Voltage fluctuations and flicker (iStoragE 5000)																															
Simulated network frequency (Hz)	50 Hz	Short circuit power $S_k$ (VA)	33 x 4.6 k																												
Plt (Maximum measured Pst)	0.14	EZE nominal power ( $P_n$ )	4.6 kVA																												
Maximum flicker coefficient $C_{\phi k}$	4.62	--	--																												
<table border="1"> <thead> <tr> <th>Pst</th> <th>#1</th> <th>#2</th> <th>#3</th> <th>#4</th> <th>#5</th> <th>#6</th> </tr> </thead> <tbody> <tr> <td>L1-N</td> <td>0.13</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> </tr> <tr> <td>Pst</td> <th>#7</th> <th>#8</th> <th>#9</th> <th>#10</th> <th>#11</th> <th>#12</th> </tr> <tr> <td>L1-N</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> <td>0.14</td> </tr> </tbody> </table>				Pst	#1	#2	#3	#4	#5	#6	L1-N	0.13	0.14	0.14	0.14	0.14	0.14	Pst	#7	#8	#9	#10	#11	#12	L1-N	0.14	0.14	0.14	0.14	0.14	0.14
Pst	#1	#2	#3	#4	#5	#6																									
L1-N	0.13	0.14	0.14	0.14	0.14	0.14																									
Pst	#7	#8	#9	#10	#11	#12																									
L1-N	0.14	0.14	0.14	0.14	0.14	0.14																									

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

Harmonics-DIN EN 61000-3-12(>16 A and ≤75 A)														
Description	Permissible individual harmonic current $I_h/I_{ref}$ % (minimum $R_{scE}=33$ )												Permissible harmonics Parameter (%)	
	Harmonics	$I_2$	$I_3$	$I_4$	$I_5$	$I_6$	$I_7$	$I_8$	$I_9$	$I_{10}$	$I_{11}$	$I_{12}$	$I_{13}$	THC/ $I_{ref}$
Limit value	8.0	21.6	4.0	10.7	2.67	7.2	2.0	3.8	1.6	3.1	1.33	2.0	23	23
Actual value	1.669	0.186	1.289	0.181	0.764	0.165	0.445	0.175	0.458	0.19	0.314	1.669	6.172	1.032

Harmonics-DIN EN 61000-3-2(≤16 A) (iStorageE 3600)												
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100	Limit value
Ordinal number	A	A	A	A	A	A	A	A	A	A	A	A
2	0.010	0.011	0.035	0.028	0.036	0.040	0.040	0.038	0.034	0.030	0.024	1.080
3	0.272	0.097	0.224	0.164	0.195	0.240	0.257	0.273	0.291	0.313	0.339	2.300
4	0.007	0.005	0.032	0.024	0.032	0.038	0.037	0.037	0.032	0.028	0.022	0.430
5	0.174	0.270	0.211	0.128	0.105	0.112	0.111	0.111	0.118	0.130	0.146	1.140
6	0.004	0.005	0.036	0.026	0.035	0.041	0.041	0.039	0.035	0.031	0.025	0.300
7	0.105	0.136	0.122	0.092	0.082	0.090	0.088	0.088	0.092	0.100	0.112	0.770
8	0.001	0.003	0.037	0.023	0.030	0.036	0.037	0.036	0.032	0.029	0.024	0.230
9	0.067	0.070	0.052	0.048	0.054	0.069	0.073	0.076	0.082	0.089	0.098	0.400
10	0.002	0.002	0.035	0.020	0.027	0.032	0.034	0.034	0.031	0.027	0.022	0.184
11	0.044	0.046	0.063	0.015	0.032	0.053	0.061	0.065	0.071	0.078	0.086	0.330
12	0.001	0.002	0.032	0.024	0.030	0.034	0.035	0.035	0.032	0.029	0.024	0.153
13	0.026	0.018	0.068	0.007	0.012	0.038	0.050	0.056	0.062	0.069	0.079	0.210
14	0.002	0.002	0.029	0.016	0.023	0.026	0.027	0.027	0.024	0.022	0.018	0.131
15	0.014	0.011	0.049	0.009	0.013	0.025	0.040	0.048	0.056	0.064	0.072	0.150
16	0.002	0.003	0.030	0.013	0.020	0.023	0.024	0.025	0.024	0.022	0.018	0.115
17	0.008	0.012	0.033	0.006	0.019	0.019	0.033	0.041	0.048	0.055	0.063	0.132
18	0.001	0.002	0.029	0.011	0.019	0.023	0.024	0.024	0.023	0.021	0.018	0.102
19	0.003	0.014	0.038	0.008	0.022	0.020	0.026	0.035	0.042	0.049	0.057	0.118
20	0.001	0.003	0.025	0.011	0.018	0.022	0.023	0.023	0.022	0.020	0.018	0.092
21	0.006	0.017	0.033	0.012	0.019	0.020	0.020	0.029	0.036	0.043	0.051	0.107
22	0.001	0.003	0.022	0.008	0.015	0.019	0.020	0.020	0.019	0.018	0.015	0.084
23	0.007	0.021	0.021	0.014	0.015	0.021	0.018	0.024	0.031	0.038	0.045	0.098
24	0.002	0.003	0.022	0.005	0.012	0.016	0.017	0.017	0.016	0.015	0.013	0.077
25	0.009	0.021	0.019	0.011	0.011	0.020	0.017	0.020	0.026	0.033	0.039	0.090
26	0.001	0.003	0.019	0.006	0.012	0.015	0.016	0.016	0.015	0.014	0.012	0.071
27	0.009	0.020	0.019	0.006	0.009	0.016	0.014	0.015	0.021	0.027	0.033	0.083
28	0.001	0.002	0.017	0.005	0.011	0.013	0.015	0.014	0.013	0.013	0.012	0.066
29	0.011	0.021	0.015	0.006	0.010	0.014	0.015	0.014	0.019	0.024	0.030	0.078
30	0.001	0.003	0.017	0.003	0.010	0.012	0.013	0.013	0.012	0.012	0.010	0.061
31	0.010	0.020	0.012	0.007	0.009	0.010	0.012	0.011	0.014	0.019	0.024	0.073
32	0.001	0.002	0.017	0.004	0.008	0.010	0.012	0.011	0.010	0.010	0.009	0.058
33	0.009	0.019	0.014	0.007	0.007	0.006	0.010	0.010	0.012	0.016	0.021	0.068
34	0.001	0.002	0.015	0.004	0.007	0.008	0.009	0.010	0.009	0.008	0.007	0.054
35	0.009	0.017	0.013	0.005	0.005	0.004	0.008	0.008	0.010	0.013	0.017	0.064
36	0.002	0.003	0.015	0.004	0.005	0.007	0.008	0.009	0.008	0.008	0.008	0.051
37	0.010	0.016	0.013	0.002	0.003	0.003	0.006	0.007	0.008	0.011	0.014	0.061
38	0.001	0.002	0.014	0.004	0.004	0.005	0.007	0.007	0.007	0.006	0.005	0.048
39	0.010	0.015	0.015	0.002	0.003	0.002	0.004	0.005	0.006	0.008	0.011	0.058
40	0.002	0.002	0.013	0.004	0.003	0.004	0.005	0.006	0.006	0.006	0.005	0.046

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

Harmonics-DIN EN 61000-3-12(>16 A and ≤75 A) (iStorageE 5000)												
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100	Limit value
Ordinal number	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	[%]
2	0.054	0.137	0.138	0.126	0.126	0.113	0.106	0.096	0.092	0.079	0.070	8%
3	0.920	1.164	0.639	0.744	0.928	1.004	1.108	1.233	1.361	1.506	1.669	21.6%
4	0.025	0.171	0.186	0.154	0.177	0.160	0.141	0.128	0.113	0.104	0.082	4%
5	0.933	1.289	0.415	0.374	0.527	0.587	0.632	0.678	0.745	0.815	0.905	10.7%
6	0.036	0.137	0.175	0.169	0.181	0.175	0.167	0.164	0.154	0.144	0.128	2.67%
7	0.524	0.764	0.507	0.368	0.379	0.377	0.389	0.411	0.444	0.489	0.531	7.2%
8	0.021	0.165	0.138	0.131	0.142	0.130	0.128	0.112	0.103	0.088	0.067	2%
9	0.316	0.383	0.369	0.252	0.277	0.316	0.314	0.331	0.368	0.403	0.445	3.8%
10	0.016	0.175	0.142	0.106	0.125	0.118	0.107	0.097	0.088	0.072	0.055	1.6%
11	0.163	0.458	0.241	0.150	0.199	0.256	0.301	0.349	0.365	0.363	0.373	3.1%
12	0.038	0.190	0.093	0.092	0.120	0.121	0.119	0.114	0.108	0.099	0.079	1.33%
13	0.153	0.310	0.066	0.193	0.195	0.176	0.169	0.222	0.272	0.306	0.314	2%
14	0.044	0.106	0.162	0.107	0.092	0.079	0.060	0.037	0.027	0.037	0.039	-
15	0.053	0.221	0.090	0.103	0.114	0.246	0.318	0.351	0.366	0.371	0.408	-
16	0.056	0.157	0.071	0.061	0.098	0.116	0.124	0.129	0.128	0.118	0.107	-
17	0.094	0.170	0.075	0.088	0.099	0.150	0.156	0.111	0.084	0.066	0.068	-
18	0.045	0.128	0.088	0.094	0.078	0.061	0.043	0.031	0.031	0.042	0.050	-
19	0.062	0.080	0.139	0.087	0.041	0.087	0.126	0.145	0.153	0.190	0.242	-
20	0.025	0.088	0.074	0.027	0.061	0.066	0.069	0.073	0.065	0.055	0.046	-
21	0.042	0.034	0.066	0.067	0.066	0.127	0.152	0.182	0.203	0.215	0.254	-
22	0.019	0.077	0.085	0.057	0.051	0.050	0.050	0.053	0.060	0.065	0.062	-
23	0.037	0.065	0.035	0.045	0.042	0.106	0.156	0.197	0.220	0.219	0.235	-
24	0.017	0.053	0.066	0.037	0.063	0.071	0.071	0.068	0.063	0.054	0.044	-
25	0.062	0.087	0.043	0.037	0.070	0.078	0.100	0.128	0.153	0.165	0.195	-
26	0.013	0.056	0.070	0.037	0.045	0.047	0.053	0.061	0.061	0.061	0.052	-
27	0.054	0.081	0.026	0.033	0.060	0.052	0.075	0.092	0.128	0.155	0.172	-
28	0.019	0.039	0.053	0.033	0.045	0.050	0.054	0.049	0.054	0.048	0.044	-
29	0.051	0.103	0.039	0.033	0.055	0.033	0.053	0.074	0.110	0.127	0.151	-
30	0.017	0.041	0.050	0.023	0.034	0.038	0.037	0.040	0.045	0.041	0.037	-
31	0.043	0.110	0.030	0.036	0.041	0.039	0.060	0.072	0.103	0.123	0.149	-
32	0.019	0.044	0.051	0.020	0.030	0.035	0.038	0.040	0.035	0.039	0.037	-
33	0.045	0.106	0.030	0.034	0.046	0.039	0.046	0.057	0.077	0.094	0.113	-
34	0.019	0.034	0.044	0.027	0.034	0.034	0.029	0.028	0.035	0.036	0.042	-
35	0.049	0.099	0.021	0.031	0.034	0.037	0.034	0.043	0.057	0.086	0.101	-
36	0.020	0.029	0.051	0.019	0.028	0.034	0.034	0.034	0.029	0.031	0.029	-
37	0.045	0.090	0.021	0.021	0.025	0.034	0.030	0.043	0.057	0.074	0.091	-
38	0.022	0.026	0.045	0.016	0.025	0.027	0.027	0.025	0.028	0.031	0.029	-
39	0.045	0.069	0.024	0.018	0.022	0.025	0.027	0.040	0.051	0.064	0.078	-
40	0.014	0.022	0.050	0.018	0.023	0.027	0.027	0.027	0.024	0.023	0.026	-
THC/I <sub>ref</sub>	4.599	6.147	4.852	4.510	4.898	5.158	5.353	5.552	5.771	5.957	6.172	23%
PWHC/I <sub>ref</sub>	0.314	0.693	0.498	0.386	0.429	0.601	0.722	0.796	0.866	0.917	1.034	23%

Remark: I<sub>ref</sub>=20.0 A

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

## E.6 Certificate of the network and system protection

Certificate of NS protection	
<b>Manufacturer</b>	Xiamen Kehua Digital Energy Tech Co., Ltd.
<b>Type of NS protection</b>	Integrated NS protection
<b>Central NS protection</b>	No
<b>Integrated NS protection</b>	Yes Assigned to power generation unit of type: iStoragE 3600, iStoragE 5000, iStoragE 3600E, iStoragE 5000E, iStoragE1 3600, iStoragE1 5000.
<b>Network connection rule</b>	<b>VDE-AR-N 4105 “Generators connected to the low-voltage distribution network”</b> Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network
<b>Test requirement</b>	<b>DIN VDE V 0124-100 (VDE V 0124-100) “Network integration of power generation systems – Low voltage”</b> Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network
<b>Test report</b>	64.290.22.31217.01 from 2022.11.14
The network and system protection designated above meets the requirements of VDE-AR-N 4105.	



# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

## E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection "Determination of electrical properties"			
<b>NS protection test report</b>			
<b>Type of NS system:</b>	Integrated NS protection	<b>Other Manufacturer indications</b>	
<b>Software version:</b>	Software version: V1		
<b>Manufacturer:</b>	Xiamen Kehua Digital Energy Tech Co., Ltd. Room 208-38, Hengye Building No. 100 Xiangxing Road Torch High-tech Zone (Xiangan) Industrial Zone 361115 Xiamen PEOPLE'S REPUBLIC OF CHINA		
<b>Measuring period:</b>	From 2021-09-09 to 2022-01-21, 2022-10-09 to 2022-10-31		
		Inverter	
Protection function	Setting value	Tripping value	Tripping time NS protection*
Rise-in-voltage protection $U >>$	$1.25 \cdot U_n$	L1-N: 289.0 V	L1-N: 122.2 ms
Rise-in-voltage protection $U >$	$1.10 \cdot U_n$	$1.10 \cdot U_n$	ms**
Voltage drop protection $U <$	$0.8 \cdot U_n$	L1-N: 182.7 V	L1-N: 3049 ms
Voltage drop protection $U <<$	$0.45 \cdot U_n$	L1-N: 103.9 V	L1-N: 333.8 ms
Frequency decrease protection $f <$	47.5 Hz	47.49 Hz	137.6 ms
Frequency increase protection $f >$	51.5 Hz	51.51 Hz	135.6 ms
*: The tripping time includes the period from the limit value violation $U/f$ until the tripping signal to the interface switch. When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above. The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms.			
**: Verification disconnection time of moving 10-min-average value. Disconnecting time as below:			
1. 473.8 s (L1-N from 600s@ $U_n$ to 112% $U_n$ ) 2. Continuous operation (L1-N from 600s@ $U_n$ to 108% $U_n$ ) 3. 309.0 s (L1-N from 600s@106% $U_n$ to 114% $U_n$ )			
<input checked="" type="checkbox"/> <b>as integrated NS protection</b>			
Assigned to power generation unit type	iStoragE 3600, iStoragE 5000, iStoragE 3600E, iStoragE 5000E, iStoragE1 3600, iStoragE1 5000		
Integrated interface switch type	Series-connected relays for both the neutral conductor and the line conductor Relay type: HongFa, Model: HF161F-W/12-HT(477)		
Response time of interface switch for integrated NS protection	HongFa, Model: HF161F-W/12-HT(477); Release time: Max. 10 ms		





Product Service

# Certificate of Conformity

No. ESY 115067 0045 Rev. 00

Verification of the entire functional chain “integrated NS protection – interface switch” has resulted in successful disconnection.	<input checked="" type="checkbox"/>
---	-------------------------------------