



# **Compilation of Operating Regulations for MV connections of three-phase inverters SPI250K-B-H**

Brand	Xiamen Kehua Digital Energy Tech Co., Ltd.
Model	SPI250K-B-H
Serial number	Indicate the serial number of the inverter
Type	PV Inverter
FW version	ARM_V1.04 DC/AC_V1.14
N. Poles	3P
Rated Power Generation Unit (kW)	250
Nominal cosφ	> 0,99 adjustable
Nominal Voltage (V)	800
Short-Circuit Current (I <sub>cc</sub> ) (A)	238
Nominal Current (I <sub>n</sub> ) (A)	180.4
I <sub>cc</sub> /I <sub>n</sub>	1.31
X'd	N/A
No-load reactive power [Q <sub>0</sub> ]	N/A
Capacitor Power	N/A
Capacitor Insertion Mode	N/A
Start-up mode	Network automatic

The protections integrated in the inverter are regulated in a manner consistent with the external SPI (Interface Protection System) as stipulated in Annex Z, table 32, page 487 of CEI 0-16; 2019-04

Protection	Tripping threshold	Set threshold	Tripping time
59.S1	1,15 V <sub>n</sub>	920 V	> 0,5 s
59.S2	1,20 V <sub>n</sub>	960 V	> 0,1 s
27.S1	0,85 V <sub>n</sub>	680 V	> 1,5 s
27.S2	0,20 V <sub>n</sub>	160 V	> 0,5 s
81>.S1	51,5 Hz	51,5 Hz	> 1,0 s
81<.S1	47,5 Hz	47,5 Hz	> 4,0 s
81>.S2	52,5 Hz	52,5 Hz	> 0,1 s
81<.S2	46,5 Hz	46,5 Hz	> 0,1 s

### Curve P-Q capability





- END -

Xiamen Kehua Digital Energy Tech Co., Ltd.

Add: No. 457, Malong Road, Torch High-Tech Industrial Zone, Xiamen Fujian 361006 China

Tel: +86-592-5160516

Fax: +86-592-5162166

Email: [Intertrade@kehua.com](mailto:Intertrade@kehua.com)